

**Stage 2 Disinfectants and Disinfection Byproducts Rule Reporting Spreadsheet**

**Water System:** DC Water  
**PWSID:** DC0000002  
**Report Period:** 2nd Quarter 2013

- Steps: 1. Use data from three previous quarters  
 2. Enter sample date and results for current quarter of monitoring in the blue column.  
 3. Summarize results for the quarter. The number of samples should include the number of any repeat samples.

**Total Trihalomethanes (TTHM)**  
 Reported as mg/L or ppm

Number of TTHM samples taken per quarter: 12  
 Operational Evaluation Levels exceeded (Yes/No): No  
 TTHM MCL violations: No

		Three Most Recent Quarters of Sampling Results*			Current Quarter		
Scheduled Sample Month		February 2013	May 2013	August 2013	November 2013		
Actual Sample Date:		Not required					
Location ID	Location Name					Operational Evaluation Level (OEL)	Locational Running Annual Average (LRAA)
1H-9	1700 EAST CAPITOL ST NE	0.021	0.036	0.063	0.034	0.042	0.039
1H-10	900 F ST NE	0.018	0.038	0.062	0.034	0.042	0.038
2H-1 BKJV	1731 BUNKER HILL RD NE	0.018	0.036	0.061	0.032	0.040	0.037
2H-8	1801 HAMLIN ST NE	0.020	0.036	0.062	0.032	0.041	0.038
3H-4 BKJV	1640 KALMIA RD NW	0.016	0.036	0.054	0.034	0.040	0.035
3H-13	120 KENNEDY ST NW	0.014	0.035	0.051	0.031	0.037	0.033
4H-3	5701 BROAD BRANCH RD NW	0.015	0.034	0.053	0.031	0.037	0.033
A1H-3 BKJV	420 56TH ST NE	0.020	0.037	0.058	0.034	0.041	0.037
A1H-8	3125 MARTIN LUTHER KING AVE SE	0.020	0.038	0.058	0.032	0.040	0.037
L-24 DPBR**	1350 49TH ST NE	0.020	0.038	0.054	0.034	0.040	0.037
L-4	550 WATER ST SW	0.019	0.037	0.058	0.033	0.040	0.037
L-12	5000 OVERLOOK AVE SW	0.022	0.043	0.059	0.036	0.044	0.040
						If TTHM OEL is > 0.080, perform Operational Evaluation.	If TTHM LRAA is > 0.080, MCL violation occurred.

**Five Haloacetic Acids (HAA5)**  
 Reported as mg/L or ppm

Number of HAA5 samples taken per quarter: 12  
 Operational Evaluation Levels exceeded (Yes/No): No  
 HAA5 MCL violations: No

		Three Most Recent Quarters of Sampling Results*			Current Quarter		
Scheduled Sample Month		February 2013	May 2013	August 2013	November 2013		
Actual Sample Date:		Not required					
Location ID	Location Name					Operational Evaluation Level (OEL)	Locational Running Annual Average (LRAA)
1H-9	1700 EAST CAPITOL ST NE	0.023	0.024	0.042	0.021	0.027	0.028
1H-10	900 F ST NE	0.020	0.023	0.041	0.019	0.026	0.026
2H-1 BKJV	1731 BUNKER HILL RD NE	0.022	0.022	0.036	0.014	0.022	0.024
2H-8	1801 HAMLIN ST NE	0.023	0.022	0.012	0.021	0.019	0.020
3H-4 BKJV	1640 KALMIA RD NW	0.011	0.027	0.008	0.018	0.018	0.016
3H-13	120 KENNEDY ST NW	0.010	0.024	0.035	0.020	0.025	0.022
4H-3	5701 BROAD BRANCH RD NW	0.011	0.026	0.034	0.022	0.026	0.023
A1H-3 BKJV	420 56TH ST NE	0.024	0.023	0.036	0.016	0.023	0.025
A1H-8	3125 MARTIN LUTHER KING AVE SE	0.021	0.024	0.035	0.011	0.020	0.023
L-24 DPBR**	1350 49TH ST NE	0.019	0.023	0.025	0.019	0.022	0.022
L-4	550 WATER ST SW	0.021	0.022	0.034	0.019	0.024	0.024
L-12	5000 OVERLOOK AVE SW	0.022	0.028	0.018	0.022	0.023	0.023
						If HAA5 OEL is > 0.060, perform Operational Evaluation.	If HAA5 LRAA is > 0.060, MCL violation occurred.

\* Results of Stage 2 Disinfectants & Disinfection Byproduct Rule Monitoring only. Stage 1 results should not be used for LRAA or OEL.

\*\* Site L-1 BKJV (4800 Meade St NE) discontinued after May 2013, results combined with L-24 DPBR thereafter